

Certificate of Compliance

Certificate Number 20080307-E308771
Report Reference E308771, December 31, 2007
Issue Date 2008 March 7

Page 1 of 1



Issued to: **Industrias Nacionales C Por A**

Zona Industrial La Isabela
Santo Domingo
Dominican Republic

*This is to certify that
representative samples of*

Nonmetallic Conduit


The 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 4 and 6 trade sizes of schedule 40 rigid PVC conduit. Also, trade sizes 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 4 and 6 may be provided with integral couplings.

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **UL 651 Schedule 40 and 80 Rigid PVC Conduit and Fittings**

Additional Information: **Conduit may be marked "Sunlight Resistance" and/or "Max. 90°C Wire".**

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle  with the word "LISTED", a control number (may be alphanumeric) assigned by UL, and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Susan Amir*
Susan Amir, Project Handler
Underwriters Laboratories Inc.

Reviewed by: *Daniel Haiducu*
Daniel Haiducu, Sr. Project Engineer
Underwriters Laboratories Inc.